



**GREATER BANGALORE AUTHORITY**  
**BENGALURU NORTH CITY CORPORATION**  
OFFICE OF THE MEDICAL OFFICER OF HEALTH, 3<sup>rd</sup> FLOOR, MINIVIDHANSOUDHA,  
BENGALURU-64

NO: BNCC/MOH/YD/PR/17/2026-27


DATE: 19.05.2026

**SAFE DRINKING WATER AND SANITARY**  
**CONDITION CERTIFICATE**

It is certified that an inspection team headed by Medical Officer of Health and Senior Health Inspector Ward No-03 BBMP inspected the **SREE SWAMY VIVEKANANDA HIGHER PRIMARY SCHOOL**, Atturu Layout, Near Housing Board Colony, Yelahanka, Bengaluru, Karnataka-560064. Drinking water samples of Institution tested No: AESTL/25/03/W/0591 (DD No: 003459) at AES Testing Laboratory on 19.05.2026 and found that **SREE SWAMY VIVEKANANDA HIGHER PRIMARY SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the Institution Premises and the campus as per the norms prescribed by the State Government.

**The above is valid for a period of - 1 year**

  
Medical Officer of Health  
Yelahanka Division



To

The Principal  
SREE SWAMY VIVEKANANDA HIGHER PRIMARY SCHOOL,  
Atturu Layout, Near Housing Board Colony,  
Yelahanka, Bengaluru-560064.



# AES TESTING LABORATORY

(ISO 9001:2005/ISO45001:2018 Certified Laboratory)

# 44, 45, 1st Main Road, Vinayaka Nagar, Bagalagunte, Nagasandra Post, Bangalore - 560 073.  
Mob : 9538555792, 9538555283, 9000565208, Email : aestestinglaboratory@gmail.com Web : www.aeslabs.co.in

## TESTREPORT

<b>Report No:</b> AESTL/25/03/W/0591	<b>Report Date</b>	29/03/2025
<b>Issued To:</b> M/s Shree Swamy Vevekananda Higher Primary School,Attur Layout,Near Housing Board Colony,Yelahanka, Bangalore-560064.	<b>Customer Reference</b>	Verbal
	<b>Date of collection</b>	24/03/2025
	<b>Date of sample receipt</b>	24/03/2025
	<b>Date of Commencement of Analysis</b>	24/03/2025
	<b>Date of Completion of analysis</b>	26/03/2025
	<b>Sample number</b>	AESTL/25/03/W/0591
<b>Sample Collected By:</b> Customer	<b>Number of pages</b>	1 of 1
	<b>Particular of sample</b>	R.O Water

### Analytical Result

Sl. No.	Parameters	Units	Protocol APHA 24 <sup>th</sup> Edition: 2023	Results	Maximum Acceptable Limits	Maximum Permissible Limits
					(As per IS 10500: 2012)	
01	Colour	Hazen	APHA 2120 B	<5.0	5	15
02	Odour	---	APHA 2150 C	Agreeable	Agreeable	Agreeable
03	Turbidity	NTU	APHA 2130 B	<1.0	1	5
04	pH Value	---	APHA 4500 H <sup>+</sup> B	6.63	6.5-8.5	No Relaxation
05	Electrical conductivity	µs/cm	APHA 2510 B	49.0	---	---
06	Total Hardness as CaCO <sub>3</sub>	mg/L	APHA 2340 C	5.0	200	600
07	Calcium as Ca	mg/L	APHA 3500 Ca	1.2	75	200
08	Magnesium as Mg	mg/L	APHA 3500 Mg-B	<1.0	30	100
09	Chloride as Cl	mg/L	APHA 4500 Cl	8.0	250	1000
10	Total Dissolved Solids	mg/L	APHA 2540 C	31.36	500	2000
11	Sulphate as SO <sub>4</sub>	mg/L	APHA 4500 SO <sub>4</sub> -E	2.6	200	400
12	Nitrate as NO <sub>3</sub>	mg/L	IS: 3025: Part 34 -2019	<1.0	45	No Relaxation
13	Fluoride as F	mg/L	APHA 4500 F-D	0.58	1.0	1.5
14	Iron as Fe	mg/L	APHA 3500 Fe	<0.05	0.3	No Relaxation
15	Total Alkalinity as CaCO <sub>3</sub>	mg/L	APHA 2320 B	7.0	200	600

Remarks: The Sample Meets the Requirements of IS 10500:2012 (Reaffirmed 2023) Drinking Water Specification Acceptable Limit with respect to the above tested Parameter only.

**B. N. S.** \*\*\*\*\*End of the Report\*\*\*\*\*  
SECRETARY

Kammagondanahalli Sri Maruthi Seva Samithi (R)  
Reg. No.: S 107/91-92

Tested By: **Byranayakanahalli, Nelamangala Taluk, BANGALORE RURAL DISTRICT - 562 132**

**V. Sree Swamy Vivekananda**  
PRINCIPAL  
SREE SWAMY VIVEKANANDA  
HIGHER PRIMARY SCHOOL  
Attur Layout, Near Housing Board Colony, Yelahanka, Bengaluru-560064

Signature of Principal

Note : 1. The Result listed pertain only to tested samples and applicable parameters. 2. Samples will be destroyed after 15 days from the date of issue of test certificate unless & otherwise Specified. 3. This Report is not be reproduced either wholly or in part and can not be used as evidence in the count of law and should not any advertng media without prior Written permission. 4. Sampling not done by us, unless specified.